

FDD Credits - 415 W. Washington

Unit Type	Building Size (gross square foot)	Table A Design Dry Weather Flow Rate	gallons per day
Non-Medical Office	16,300.00	0.06	978.00
Warehouse	15,200.00	0.02	304.00
			1,282.00

Total Flow	1,282.00	gpd
Peak Flow	5,128.00	gpd
System Recovery Factor	-	gpd
Total Peak Flow	5,128.00	gpd
Total Peak Flow per minute	3.56	gpm

FDD Equivalent	0.89	1.00
----------------	------	------