

ADDENDUM No. 1

RFP No. 24-56

Allmendinger Park Improvements

Due: December 10, 2024, at 11:00 AM (local time)

The information contained herein shall take precedence over the original documents and all previous addenda (if any) and is appended thereto. **This Addendum includes 2 pages.**

The Proposer is to acknowledge receipt of this Addendum No. 1, including all attachments in its Proposal by so indicating in the proposal that the addendum has been received. Proposals submitted without acknowledgement of receipt of this addendum may be considered non-conforming.

The following forms provided within the RFP Document should be included in submitted proposal:

- **Attachment B – General Declarations**
- **Attachment D - Prevailing Wage Declaration of Compliance**
- **Attachment E - Living Wage Declaration of Compliance**
- **Attachment G - Vendor Conflict of Interest Disclosure Form**
- **Attachment H - Non-Discrimination Declaration of Compliance**

Proposals that fail to provide these completed forms listed above upon proposal opening may be rejected as non-responsive and may not be considered for award.

I. CORRECTIONS/ADDITIONS/DELETIONS

Changes to the RFP documents which are outlined below are referenced to a page or Section in which they appear conspicuously. Offerors are to take note in its review of the documents and include these changes as they may affect work or details in other areas not specifically referenced here.

Section/Page(s)	Change
Detailed Specifications, 01 32 14 Schedule Requirements	As provided in RFP No. 24-56 Document: Due to high use of this park during University of Michigan football season, no work will be completed between August 26, 2024 and November 10, 2024. As updated herein: Due to high use of this park during University of Michigan football season, no work will be completed between August 28, 2025 and November 30, 2025.

II. QUESTIONS AND ANSWERS

The following Questions have been received by the City. Responses are being provided in accordance with the terms of the RFP. Respondents are directed to take note in its review of the documents of the following questions and City responses as they affect work or details in other areas not specifically referenced here.

Question 1: Is the wood fence the only fencing needed?

Answer 1: Yes, wood fence is the only permanent fence needed on this project. There is also temporary construction fencing to be installed around trees during construction.

Question 2: What is the linear footage of the wooden fence? Is there a drawing or blueprint that is available?

Answer 2: As listed on sheet 7 of the plan set there is 180 linear feet of wood fence. A detail is shown on sheet 4.

Question 3: Is this line work on the east side of the site to be a wood fence or tree protection fence?

Answer 3: Line work on the east side of the site is to be temporary fencing around trees during construction.

Question 4: What is the substantial completion date?

Answer 4: The work shall be completed within 90 calendar days as identified in the contract. It is anticipated that the Notice to Proceed for this project will be issued on March 31, 2025, resulting in a final completion date of June 29, 2025.

Question 5: In the Schedule Requirements 01 33 00 Spec, you list August 26, 2024, through November 10, 2024, do these dates need to change for 2025?

Answer 5: Yes, this change has been noted in this addendum.

Question 6: Do the bleachers get attached to the sidewalk similar to the tables?

Answer 6: Yes, epoxy anchor bolt per manufacturer's recommendations as noted on the detail.

Question 7: Are saw cut joints in the sidewalk an acceptable alternative to tool joints?

Answer 7: Yes, that is acceptable.

Question 8: You have 26" diameter structures listed for the storm, as far as I know, they don't make this size. Are 24" structures acceptable?

Answer 8: 24" is acceptable.

Question 9: Do you have an Engineer's Estimate for this project?

Answer 9: No, an Engineer's Estimate is not available.

Offerors are responsible for any conclusions that they may draw from the information contained in the Addendum.