

ADDENDUM No. 1

ITB No. 4351

WWTP Secondary Effluent Pump Replacement Project

Due: January 13, 2015 by 2:00 p.m.

The following changes, additions, and/or deletions shall be made to the Invitation to Bid for WWTP Secondary Effluent Pump Replacement Project, ITB No. 4351, on which proposals will be received on/or before January 13, 2015 by 2:00 p.m.

The information contained herein shall take precedence over the original documents and all previous addenda (if any), and is appended thereto. **This Addendum includes 2 pages and no drawing(s).**

Bidder is to acknowledge receipt of this Addendum No. 1, including all attachments (if any) in its Bid by so indicating on page ITB-1 of the Invitation to Bid Form. Bids submitted without acknowledgement of receipt of this addendum will be considered nonconforming.

I. CORRECTIONS/ADDITIONS/DELETIONS

Changes to the Bid documents which are outlined below are referenced to a page or Section in which they appear conspicuously. The Bidder is to take note in its review of the documents and include these changes as they may affect work or details in other areas not specifically referenced here.

<u>Section/Page(s)</u>	<u>Change</u>
------------------------	---------------

Division 16050, Page 3, Section 3.2 A

Change second sentence; "... the five Motor Control Centers,..." to "... the four Motor Control Centers,..."

Division 16050, Page 3, Section 3.2 C

Change; "Provide six (4) bound documents..." to "Provide four (4) bound documents..."

Respondents are directed to take note in its review of the documents of the following questions and City responses as they affect work or details in other areas not specifically referenced here.

II. QUESTIONS AND ANSWERS

The following Questions have been received by the City. Responses are being provided in accordance with the terms of the ITB.

Question #1:

The specification 3.2(A) indicates the scope as being “from Unit Substation No. 4 through the five Motor Control Centers”. However, the drawings only show four motor control centers. Please clarify which MCC’s are to be included.

Answer: #1

This was a typo as there are only four MCCs.

Question #2:

The specification 3.2(A) also indicates an existing study will be provided. Please indicate if this is will be a study report (e.g. a pdf of the existing report) or if the study software model (electronic file used by modeling software) will be provided. If a study model, please indicate for which software.

Answer #2:

The existing study to be provided will be a pdf or printout of the existing report.

Question #3:

The specification 3.2(C) indicates “Provide six (4) bound documents”. Please clarify if six (6) or four (4) copies of the report are to be provided.

Answer #3:

Only four (4) bound copies of the document will be required and one (1) copy on a compact disk.

Bidders are responsible for any conclusions that they may draw from the information contained in the Addendum.