

## ADDENDUM No. 1

### ITB No. 4537

## Sanitary Manhole Rehabilitation

**Due: Wednesday, May 23, 2018 by 2:00 PM (local time)**

The following changes, additions, and/or deletions shall be made to the Invitation to Bid for Sewer Manhole Rehabilitation ITB No. 4537, on which proposals will be received on/or before May 23, 2018 at 2:00 P.M. (local time)

The information contained herein shall take precedence over the original documents and all previous addenda (if any), and is appended thereto. **This Addendum includes two (2) pages, and Pre-Bid Meeting Sign-in sheet (1 page).**

**Bidder is to acknowledge receipt of this Addendum No. 1, including all attachments in its Bid by so indicating on page ITB-1 of the Invitation to Bid Form. Bids submitted without acknowledgement of receipt of this addendum may be considered nonconforming.**

**The following forms provided within the ITB Document must be included in submitted bids at bid opening.**

- **City of Ann Arbor Prevailing Wage Declaration of Compliance**
- **City of Ann Arbor Living Wage Ordinance Declaration of Compliance**
- **Vendor Conflict of Interest Disclosure Form**
- **City of Ann Arbor Non-Discrimination Ordinance Declaration of Compliance**

**Bids that fail to provide these completed forms listed above upon bid opening will be rejected as non-responsive and will not be considered for award.**

### QUESTIONS AND ANSWERS

The following Questions have been received by the City. Responses are being provided in accordance with the terms of the ITB. Respondents are directed to take note in its review of the documents of the following questions and City responses as they affect work or details in other areas not specifically referenced here.

**Question 1:** Is the internal chimney seal to be applied over 24 vertical inches?

**Answer 1:** Yes

**Question 2:** Can Cretex External manhole chimney seal (Item 231) be used as an equal to Wrapid Seal? The Cretex external chimney seal is a pleated mechanical rubber seal that is retained at the casting frame and the precast manhole cone with stainless steel retention bands.

**Answer 2:** The City considered the steel banded rubber seals during design and has determined that the product specified in the contract documents can be adapted over a variety of old structures that could be encountered during rehabilitation.

**Question 3:** Can Flex Seal Utility Sealant Internal Chimney Seal be used?

**Answer 3:** The product does not meet all specified cured properties.

**Question 4:** Can Infi- Shield, External Uni Band be used for external manhole chimney seal?

**Answer 4:** The product can be used, provided that the coverages and overlaps specified in the contract documents are complied with.

**Question 5:** Can the following materials be used:  
Item # 255 – Manhole Cementitious Liner- A.W Cook CAM (Calcium Aluminate Mortar)  
Item #260- Epoxy Liner – Sherwin Williams DURAPLATE 6100 High Strength-High Build Amine Cured Epoxy Liner  
Item #230- Internal Chimney Seal- Sherwin Williams Envirolastic AR 530 Chimney Seal

**Answer 5:** Item 255 – The product meets specifications. Approval of the product is subject to approval of the required contractor submittals.  
Item 260 –Product does not meet specified tensile strength.  
Item 230 –The product does not meet all specified cured properties.

**Question 6:** I didn't see the prevailing wage rates listed in the contract documents. Can you provide a website link or current list of prevailing wage rates to be used for this contract? Are we to use Davis Bacon wage rate or Washtenaw County prevailing wage rates??

**Answer 6:** Davis Bacon wage rates. <https://www.wdol.gov/dba.aspx>

**Question 7:** If a concrete collar were to be poured around the adjusting rings and frame, thus essentially using the concrete as sub base for the asphalt would you accept (conventional full depth sawcutting) as equal to the circular core method described on DS-10.

**Answer 7:** The existing bituminous pavement shall be removed with the circular core saw, and concrete shall be backfilled around the structure as per the specifications for item #220.

Respondents are responsible for any conclusions that they may draw from the information contained in the Addendum.

## PREBID MEETING SIGN-IN SHEET

PROJECT: Sanitary Manhole Rehabilitation

ITB #4537

Thursday, May 10, 2018

MEETING SIGN-IN SHEET

PLEASE PRINT

NAME	REPRESENTING	MAILING ADDRESS	TELEPHONE	EMAIL
KEVIN APPEL	ART	Address: 01116 LTV RD 17	Office: 419-636-2684	KAPPEL @ ART COATINGTECH.COM
		City, State: Bryan, OH Zip: 43506	Cell: 419-553-7047	
Jordan Bidigare	Bidigare Contractors	Address: 939 S. Mill St	Office: 248-735-1113	Jordan@Bidigare Contractors.COM
		City, State: Plymouth, MI Zip: 48170	Cell: 734-476-4461	
Stephen Belus	Lake County Sewer Company	Address: 32900 Lakeland Blvd	Office: 440-585-5957	FrankK@lakecounty Sewer.COM
		City, State: willowick, OH Zip: 44095	Cell:	
BILL HEFFERNAN	FRONT RANGE ENVIRONMENTAL	Address: 2110 WRIGHT	Office: 815-455-1042	BHEFFERNAN@ FRONT RANGE ENVIRONMENTAL.COM
		City, State: McHenry, IL Zip: 60050	Cell: 847-366-3517	
DUSTON KIRKE	E.T. MACKENZIE COMPANY	Address: 6400 JACKSON Rd.	Office: 734.761.5050	dkirke@mackenzieco.com
		City, State: Anna Arbor, MI Zip: 48103	Cell: 517.499.6248	
Brett Vallow	KIM Const Co. INC	Address: 3142 Holman Ave	Office: 708-754-1181	info@kimconstruction COM
		City, State: Steger, IL Zip: 60475	Cell: 708-275-2052	
Ammar Hamany	A2	Address: 301 S. Huron st	Office:	ahamany@azgov.org
		City, State: Zip:	Cell: 734-330-1292	
Bob Horton	Sherwin- williams	Address: 3976 Brookstone	Office:	Robert.J. Horton @Sherwin.COM
		City, State: Canton, MI Zip: 48188	Cell: 724-714-4653	