

February 19, 2013

**ADDENDUM NO. 1
TO THE
INVITATION TO BID (ITB) 4269
2013 STREET RESURFACING PROJECT
FOR THE
CITY OF ANN ARBOR, MICHIGAN**

The following changes, additions, and/or deletions shall be made to the ITB 4269 for the 2013 Street Resurfacing Project, for the City of Ann Arbor, Michigan.

The information contained herein shall take precedence over the original documents and all previous addenda, and is appended thereto. **This Addendum includes 1 page(s) and 0 drawing(s).**

The Contractor is to acknowledge receipt of this Addendum No. 1 on page P-1 of the Bid Documents prior to submitting its Proposal.

Changes in the Bid Documents which are outlined below are referenced to a page or drawing in which they appear conspicuously. The Bidder is to take note in its review of the documents and include these changes as they affect work or details in other areas not specifically referenced here.

Item #1: Contract Documents, Detailed Specifications, Page DS-45;
Under “Adjust Structure Cover” add the following paragraph:

“The HMA leveling surface is to be saw cut for removal before adjusting structure covers. This work shall be included in the cost of the Adjust Structure Cover item.”

Item #2: Contract Documents, Detailed Specifications, Page DS-56;
Add the following paragraph:

*“Portable Changeable Message Signs
The Contractor shall provide the City with the ability to program the message boards directly, so that the City does not need to rely on the Contractor to make the changes to the message.”*

Item #3: Contract Documents, Plan Set, Sheet 3 (State Street Cover Page);
Change the quantity for Item 218 – Stress Adsorbing Membrane Interlayer from “12,564 SY” to “**0 SY**”:

Item #4: Contract Documents, Plan Set, Sheet 67 (Barton Cover Page);
Change the quantity for Item 218 – Stress Adsorbing Membrane Interlayer from “9228 SY” to “**0 SY**”: