


NOTE: MINIMUM BLOW-OFF SIZE SHALL BE 2". IF NO OTHER MAJOR BLOW-OFF (I.E. HYD.) AVAILABLE, SIZE SHALL BE ADEQUATE TO PROVIDE FULL FLUSHING OF MAIN.

REVISIONS		REV. NO.	DR. BY	CH. BY	DATE
PUBLIC SERVICES DEPARTMENT CITY OF ANN ARBOR					
TEMPORARY TESTING BLOW-OFF					
DR. BY	D.F.	CH. BY	C.S.S.	DRAWING NO.	
SCALE	NONE	DATE	11-6-92	SD-W-7	
INCH	0  1			SHEET NO. _____ OF _____	