

ADDENDUM No. 1

ITB No. 4381

WATER TREATMENT PLANT CHEMICAL BID CARBON DIOXIDE (CO₂)

Due: April 30, 2015 at 2:00PM

The following changes, additions, and/or deletions shall be made to the Invitation to Bid for Water Treatment Plant Chemical Bid, Carbon Dioxide (CO₂), ITB No. 4381, on which proposals will be received on/or before April 30, 2015 by 2:00 p.m.

The information contained herein shall take precedence over the original documents and all previous addenda (if any), and is appended thereto. **This Addendum includes 2 pages.**

Bidder is to acknowledge receipt of this Addendum No. 1, including all attachments (if any) in its Bid by so indicating on the Invitation to Bid Form. Bids submitted without acknowledgement of receipt of this addendum will be considered nonconforming.

I. Clarifications

Changes to the Bid documents which are outlined below are referenced to a page or Section in which they appear conspicuously. The Bidder is to take note in its review of the documents and include these changes as they may affect work or details in other areas not specifically referenced here.

Page 12, 3rd paragraph (bid form)
"Carbon Dioxide" should be substituted for "Liquid Oxygen"

II. QUESTIONS AND ANSWERS

Respondents are directed to take note in its review of the documents of the following questions and City responses as they affect work or details in other areas not specifically referenced here.

The following Questions have been received by the City. Responses are being provided in accordance with the terms of the ITB.

- 1.) Who is your current supplier?
RESPONSE: Continental Carbonic
- 2.) What is your current pricing?
RESPONSE: \$51.34/ton
- 3.) Do you own your tank(s)? If so, what size?
RESPONSE: Yes. 70 Ton and 30 Ton

4.) What was your actual annual consumption in 2014?

RESPONSE: 454.4T for FY 2014

5.) QVL F was removed from the AWWA Standard with the 510-06 revision and values for QVL G, H, and I were updated. Current Standard is AWWA 510-12 and the 99.5 percent by weight referenced in your bid is linked with QVL H. Please confirm that AWWA 510-12 QVL H is the specification required.

RESPONSE: Yes, the AWWA 510-12 QVL H is the specification required

Bidders are responsible for any conclusions that they may draw from the information contained in the Addendum.