

ADDENDUM No. 2

ITB No. 4555

Riverview Drive Sanitary Sewer and Water Main Extension Project

Bids Due: November 30, 2018 at 2:00 P.M. (Local Time)

The following changes, additions, and/or deletions shall be made to the Invitation to Bid for the Riverview Drive Sanitary Sewer and Water Main Extension Project, ITB No. 4555, on which proposals will be received on/or before November 30, 2018, at 2:00 P.M. (local time).

The information contained herein shall take precedence over the original documents and all previous addenda (if any), and is appended thereto. **This Addendum includes 2 pages.**

Bidder is to acknowledge receipt of this Addendum No. 2, including all attachments (if any) in its Bid by so indicating on page ITB-1 of the Invitation to Bid Form. Bids submitted without acknowledgment of receipt of this addendum will be considered nonconforming.

The following forms provided within the ITB document must be included in submitted bids:

- City of Ann Arbor Prevailing Wage Declaration of Compliance
- City of Ann Arbor Living Wage Ordinance Declaration of Compliance
- Vendor Conflict of Interest Disclosure Form
- City of Ann Arbor Non-Discrimination Ordinance Declaration of Compliance

Bids that fail to provide these completed forms listed above upon bid opening will be rejected as non-responsive and will not be considered for award.

I. CORRECTIONS/ADDITIONS/DELETIONS

Changes to the Bid document which are outlined below are referenced to a page or Section in which they appear conspicuously. The Bidder is to take note in its review of the documents and include these changes as they may affect work or details in other areas not specifically referenced here.

<u>Section/Page(s)</u>	<u>Change</u>
-------------------------------	----------------------

	No changes are being made to the bid documents with this Addendum. This Addendum answers a question raised at the Pre-bid Meeting.
--	---

II. QUESTIONS AND ANSWERS

The following Questions have been received by the City. Responses are being provided in accordance with the terms of the ITB. Offerors are directed to take note in their review of the documents of the following questions and City responses as they affect work or details in other areas not specifically referenced here.

Question 1: Does the required testing of the sanitary sewer and service leads need to be performed in the order as described in the section entitled “Sewer Testing” on page DS-138 of the contract documents?

Answer 1: *The City of Ann Arbor will allow the Contractor to perform the required air testing of the sanitary sewer prior to the required mandrel testing. However, if the mandrel testing results in deflection of the sanitary sewer that will not allow the mandrel to pass, then the air test will be required to be performed again in order to ensure that the pipe hasn't been compromised during its repair. The video testing must be performed after the air and mandrel testing has been completed. The 4" diameter sanitary sewer leads are not required to be televised.*

Respondents are responsible for any conclusions that they may draw from the information contained in the Addendum.